City of Wichita, Kansas Americans with Disabilities Act Transition Plan

Big Arkansas River Park

August 2005



Prepared by

DMCG

Disability Management Consulting Group L.L.C. 2801 Jonquil Place

Columbia, MO 65202

In conjunction with

The Great Plains ADA & IT Center and the City of Wichita Disability Advisory Board

<u>City of Wichita – ADA/504 Transition Plan – Big Arkansas River Park - August 2005</u>

Legend: Blue font identifies hyperlinked documents – Red font indicates recommended changes to structures or policies

Locations	Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access	Criteria – L=low, M=medium, H=high		_	Supplemental Technical Information		Finalized Actions			
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed (Include initial)
1. Parking	Accessible parking does not exist due to a gravel surface and lack of upright signage.	4.1.2(5)(a), (b), 4.6	If parking spaces are provided for self-parking by employees or visitors, or both, then accessible spaces complying with <u>4.6</u> shall be provided in each such parking area in conformance with the table shown in <u>(5)(a)</u> . In addition, One in every eight accessible spaces, but not less than one, shall be served by an access aisle 96 in (2440 mm) wide minimum and shall be designated "van accessible." Ensure at least one van accessible parking space exists in the parking lot serving this trail.	L	L	M	1	\$500	(See Accessible Parking Detail – Attachment A and Parking Technical Bulletin, for greater clarification).			
2. Pedestrian Paths	An accessible path of travel does not exist leading from the parking area to the trail due to dirt/grass surfaces.	4.3	According to ADAAG, At least one accessible route complying with 4.3 shall be provided within the boundary of the site from public transportation stops, accessible parking spaces, passenger loading zones if provided, and public streets or sidewalks, to an accessible building entrance. At least one accessible route complying with 4.3 shall connect accessible buildings, accessible facilities, accessible elements, and accessible spaces that are on the same site. An accessible route must be stable, firm and slip-resistant (rubber, concrete or asphalt). Ensure that an accessible path of travel exists leading to all public facilities.	L	L	M	2	\$1,00 0	ADAAG			

City of Wichita – ADA/504 Transition Plan – Big Arkansas River Park - August 2005

Legend: Blue font identifies hyperlinked documents – Red font indicates recommended changes to structures or policies

Locations	Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access	Criteria — L=low, M=medium, H=high				mental Technical nformation	Finalized Actions			
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed (Include initial)
3. Trail	Steep cross slopes exist along portions of the walking surface (trail) measuring from 3% to 7%. Steep running slopes exist along the trail measuring from 10% to 18%.	ODA- 16.2 4.3	The Accessibility Guidelines for Outdoor Developed Areas" (AGODA) does provide both scoping and specifications for accessible trails. These Guidelines (AGODA) are neither final rules, nor enforceable. Generally, we consider trails and other park amenities for use by the general public to be services provided by local governments, which own or operate the trail. Therefore, to ensure compliance with Title II's program access requirements, we recommend following the scoping and specifications provided by the AGODA to determine the accessibility of trails. We recommend ensuring that a portion (an existing area without steep running slopes)) of the trail surface be made fully accessible and usable according to ADAAG and/or the Accessibility Guidelines for Outdoor Areas; so that individuals with disabilities are provided an experience similar to how others without disabilities would experience this trail; if doing so is technically feasible and does not detract from the overall intent of the trail.	L ®	L	M	3 4 5	\$3,00 0	Outdoor Developed Areas (AGODA) ADAAG New ADAAG			

Big Arkansas River Park - Conceptual Cost Projections

Total	\$4,500
Year One (Very High)	\$0
Year Three (High)	\$0
Year Five (Medium)	\$0
Year Ten (Low)	\$4,500